

CERTIFICATE OF COMPLIANCE(UL)

CERTIFICATE OF COMPLIANCE

Certificate Number 20190507-EX26867
Report Reference EX26867-20150831
Issue Date 2019-May-7

Issued to: Shandong Zihua Pipe Industry Co Ltd
Zhang Jia Village, Fang An Subdistrict, Fang Zi District,
Weifang,
Shandong 262113 CHINA

This is to certify that
representative samples of

FITTINGS, RUBBER GASKETED

Refer Addendum Page For Models/Product

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 213 - Rubber Gasketed Fittings for Fire-Protection
Service
ULC/ORD 213 - Rubber Gasketed Fittings for Fire-
Protection Service

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

Page 1 of 5



원본대조필



CERTIFICATE OF COMPLIANCE(UL)

CERTIFICATE OF COMPLIANCE

Certificate Number 20190507-EX26867
Report Reference EX26867-20150831
Issue Date 2019-May-7

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Rigid Coupling

XGQT1	Rolled	10	1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 6, 8, 10;	300
XGQT1	Rolled, Cut	40	1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 6, 8, 10, 12;	300
XGQT1	Cut, Rolled	GB/T3091	3OD(76.1mm), 4-1/4OD(108.1mm), 5-1/4OD(133mm), 5-1/2OD(139.7mm), 6-1/4OD(159mm), 6-1/2OD(165.1mm);	300
XGQT2	Rolled	10	1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8, 10	300
XGQT2	Rolled, Cut	40	1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8, 10, 12	300
XGQT2	Rolled, Cut	GB/T3091	3OD(76.1mm), 4-1/4OD(108.1 mm), 5-1/4OD(133 mm), 5-1/2OD(139.7 mm), 6-1/4OD(159mm), 6-1/2OD(165.1mm)	300

Flexible Coupling

Model	Groove Type	Pipe	Size (in.)	Rated Pressure (psig)
XGQT1N	Rolled	10	1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8, 10	300
XGQT1N	Rolled, Cut	40	1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8, 10, 12	300
XGQT1N	Rolled, Cut	GB/T3091	3OD(76.1mm), 4-1/4OD(108.1 mm), 5-1/4OD(133 mm), 5-1/2OD(139.7 mm), 6-1/4OD(159mm), 6-1/2OD(165.1mm)	300

Reducing Flexible Coupling

Model	Groove Type	Pipe	Size (in.)	Rated Pressure (psig)
XGQT1B	Rolled	10	2-1/2 x 2; 3 x 2, 2-1/2; 4 x 2, 2-1/2, 3OD, 3; 6 x 3, 4; 8 x 6-1/2OD, 6	300
XGQT1B	Rolled, Cut	40	2-1/2 x 2;	300

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

Page 2 of 5



원본대조필



CERTIFICATE OF COMPLIANCE(UL)

CERTIFICATE OF COMPLIANCE

Certificate Number 20190507-EX26867
Report Reference EX26867-20150831
Issue Date 2019-May-7

			3 x 2, 2-1/2; 4 x 2, 2-1/2, 3OD, 3; 6 x 3, 4; 8 x 6-1/2OD, 6	
XGQT1B	Rolled, Cut	GB/T3091	3OD x 2; 6-1/2OD x 4	300

Flange Adapter

Model	Groove Type	Pipe	Size (in.)	Rated Pressure (psig)
XGQT08	N/A	10,40	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12	300
XGQT08	N/A	GB/T 3091	3OD(76.1mm), 4-1/4OD(108.1 mm), 5-1/4OD(133 mm), 5-1/2OD(139.7 mm), 6-1/4OD(159mm), 6-1/2OD(165.1mm)	300



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

Page 3 of 5



원본대조필



CERTIFICATE OF COMPLIANCE(UL)

CERTIFICATE OF COMPLIANCE

Certificate Number 20190507-EX26867
Report Reference EX26867-20150831
Issue Date 2019-May-7

Mechanical Tee

Model	Groove Type	Pipe	Size (in.)	Rated Pressure (psig)
XGQT3	Grooved	10,40	2 x 1-1/4, 1-1/2; 2-1/2 x 1-1/4, 1-1/2; 3 x 1-1/4, 1-1/2, 2; 4 x 1, 1-1/4, 1-1/2, 2, 2-1/2, 3OD(76.1mm), 5 x 1-1/4, 1-1/2, 2, 3OD; 6 x 1-1/4, 1-1/2, 2, 2-1/2, 3OD(76.1mm), 3, 4; 8 x 2, 3OD(76.1mm), 3, 4	300
XGQT3	Grooved	GB/T 3091	3OD(76.1mm) x 1-1/4, 1-1/2; 4-1/4OD(108.1 mm) x 3OD(76.1mm), 3; 5-1/2OD(139.7 mm) x 1-1/4, 1-1/2, 2, 3OD(76.1mm), 3; 6-1/2OD(165.1mm)x 1-1/4, 1-1/2, 2, 3OD(76.1mm), 3, 4	300
XGQT3S	Threaded	10,40	2 x 1, 1-1/4; 2-1/2 x 1, 1-1/4, 1-1/2; 3 x 1, 1-1/4, 1-1/2, 2; 4 x 1, 1-1/4, 1-1/2, 2, 2-1/2, 3OD(76.1mm), 5 x 1, 1-1/4, 1-1/2, 2, 3OD, 3; 6 x 1, 1-1/4, 1-1/2, 2, 2-1/2, 3OD, 3; 8 x 1, 1-1/4, 1-1/2, 2, 3OD(76.1mm), 3, 4	300
XGQT3S	Threaded	GB/T 3091	3OD(76.1mm) x 1, 1-1/4, 1-1/2; 4-1/4OD(108.1 mm) x 1, 1-1/4, 1-1/2, 2, 2- 1/2, 3OD(76.1mm), 3; 5-1/4OD(133 mm) x 1, 1-1/4, 1-1/2, 2, 3OD(76.1mm), 3; 5-1/2OD(139.7 mm) x 1, 1-1/4, 1-1/2, 2, 3OD(76.1mm), 3; 6-1/4OD(159mm) x 1, 1-1/4, 1-1/2, 2, 3OD(76.1mm), 3; 6-1/2OD(165.1mm) x 1, 1-1/4, 1-1/2, 2, 3OD(76.1mm), 3	300

Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

Page 4 of 5



원본대조필



CERTIFICATE OF COMPLIANCE(UL)

CERTIFICATE OF COMPLIANCE

Certificate Number 20190507-EX26867
Report Reference EX26867-20150831
Issue Date 2019-May-7

XGQT3U	Threaded	10,40	1 x 1/2; 1-1/4 x 1/2, 3/4, 1; 1-1/2 x 1/2, 3/4, 1; 2 x 1/2, 3/4, 1, 1-1/4; 2-1/2 x 1/2, 3/4; 3 x 1	300
XGQT3U	Threaded	GB/T 3091	30D x 1/2, 3/4, 1	300

Models XGQT3S and XGQT3U in the 1/2 in., 3/4 in. and 1 in., nominal outlet sizes are intended for direct connection to sprinklers.

Models XGQT3, XGQT3S and XGQT3U in the 1 in. and larger nominal outlet sizes are intended for connection to system piping.

10 refers to Schedule 10 steel pipe in accordance with NFPA 13

40 refers to Schedule 40 steel pipe in accordance with NFPA 13

GB/T 3091 refers to steel pipe manufactured in accordance with GB/T 3091



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

Page 5 of 5



원본대조필



CERTIFICATE OF COMPLIANCE(UL)

CERTIFICATE OF COMPLIANCE

Certificate Number 20160914-EX26750
Report Reference EX26750-20150831
Issue Date 2016-SEPTEMBER-14

Issued to: Shandong Zihua Pipe Industry Co Ltd
Zhang Jia Village, Fang An Subdistrict, Fang Zi District
Weifang
Shandong 262113 CHINA

This is to certify that representative samples of

FITTINGS, GROOVED AND PLAIN END
See Addendum Pages

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 213C, Grooved and Plain End Fittings
ULC/ORD 213, Rubber Gasketed Fittings for Fire-
Protection Service

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.


Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

Page 1 of 5



원본대조필



CERTIFICATE OF COMPLIANCE(UL)

CERTIFICATE OF COMPLIANCE

Certificate Number 20160914-EX26750
Report Reference EX26750-20150831
Issue Date 2016-SEPTEMBER-14

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Grooved end ductile iron fittings for use with WEIFANG ZHHUA ECONOMICAL TRADE CO LTD's (EX26867) Listed rubber gasketed fittings for sizes and working pressures

Model	Fitting Type	Size, in. (mm)	Rated Pressure, psi
XGQT01	90 DEG. ELBOW	1, 1-1/4, 1-1/2, 2, 2-1/2, 3OD(76.1mm), 3, 4-1/4OD(108.1mm), 4, 5-1/4OD(133mm), 5-1/2OD(139.7mm), 6-1/4OD(159mm), 6-1/2OD(165.1mm), 6, 8, 10, 12	300
XGQT02	45 DEG. ELBOW	1, 1-1/4, 1-1/2, 2, 2-1/2, 3OD(76.1mm), 3, 4-1/4OD(108.1mm), 4, 5-1/4OD(133mm), 5-1/2OD(139.7mm), 6-1/4OD(159mm), 6-1/2OD(165.1mm), 6, 8	300
XGQT09	22.5 DEG. ELBOW	4, 6-1/2OD(165.1mm), 8,	300
XGQT9	11.25 DEG. ELBOW	4, 6-1/2OD(165.1mm), 8,	300
XGQT07	EQUAL CROSS	2, 2-1/2, 3OD(76.1mm), 3, 4, 1/2OD(139.7mm), 6-1/4OD(159mm), 6-1/2OD(165.1mm), 6, 8,	300
XGQT7	GROOVED REDUCING CROSS	5-1/2OD(139.7mm) x 4, 6-1/2OD(165.1mm) x 4;	300
XGQT7S	THREADED REDUCING CROSSES	4 x 1, 1-1/4, 1-1/2, 2, 3OD(76.1mm), 3; 5-1/2OD(139.7mm) x 1-1/4, 1-1/2, 2, 3OD(76.1mm), 3, 6-1/2OD(165.1mm) x 1, 1-1/4, 1-	300

Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

Page 2 of 5



원본대조필



CERTIFICATE OF COMPLIANCE(UL)

CERTIFICATE OF COMPLIANCE

Certificate Number 20160914-EX26750
Report Reference EX26750-20150831
Issue Date 2016-SEPTEMBER-14

XGQT06	END CAP	1/2, 2, 3OD(76.1mm), 3 1, 1-1/4, 1-1/2, 2, 3OD(76.1mm), 3, 4, 5-1/2OD(139.7mm), 6- 1/2OD(165.1mm), 6, 8	300
XGQT5	GROOVED CONCENTRIC REDUCER	2 x 1, 1-1/4, 1-1/2; 2-1/2 x 1, 1-1/4, 1-1/2; 3OD(76.1mm) x 1, 1-1/4, 1- 1/2, 2; 3 x 1, 1-1/4, 1-1/2, 2, 2-1/2, 3OD(76.1mm); 4-1/4OD(108mm) x 3OD(76.1mm), 3; 4 x 2, 2-1/2, 3OD(76.1mm), 3; 133 mm x 4-1/4OD(108mm), 4; 5-1/2OD(139.7mm) x 2, 3OD(76.1mm), 3, 4; 6-1/4 OD(159.1mm) x 2, 3OD(76.1mm), 3, 4-1/4OD(108mm), 4, 133mm; 6-1/2OD(165.1mm) x 2, 3OD(76.1mm), 3, 4, 5- 1/2OD(139.7mm); 6 x 2, 2-1/2, 3OD(76.1mm), 3, 4, 5-1/2OD(139.7mm); 8 x 2, 3OD(76.1mm), 3, 4, 5- 1/2OD(139.7mm), 6-1/2OD(165.1mm), 6;	300
XGQT5S	THREADED CONCENTRIC REDUCER	2 x 1, 1-1/4, 1-1/2; 2-1/2 x 1, 1-1/4, 1-1/2, 2; 3OD(76.1mm) x 1, 1-1/4, 1-1/2, 2; 3 x 1, 1-1/4, 1-1/2, 2, 2-1/2, 3OD(76.1mm); 4-1/4OD(108.1mm) x 1, 1-1/4, 1- 1/2, 2, 3OD(76.1mm), 3; 4 x 1, 1-1/4, 1-1/2, 2, 2-1/2, 3OD(76.1mm), 3; 5-1/2OD(139.7mm) x 1, 1-1/4, 1-	300

Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

Page 3 of 5



원본대조필



CERTIFICATE OF COMPLIANCE(UL)

CERTIFICATE OF COMPLIANCE

Certificate Number 20160914-EX26750
Report Reference EX26750-20150831
Issue Date 2016-SEPTEMBER-14

		1/2, 2, 3OD(76.1mm), 3; 6-1/4 OD(159.1mm) x 1, 1-1/4, 1-1/2, 2, 3OD(76.1mm), 3; 6-1/2OD(165.1mm) x 1, 1-1/4, 1- 1/2, 2, 3OD(76.1mm), 3; 6 x 1, 1-1/4, 1-1/2, 2, 3OD(76.1mm), 3; 8 x 1, 1-1/4, 1-1/2, 2, 3OD(76.1mm), 3, 4;	
XGQT05	ECCENTRIC R EDUCER	6-1/2OD(165.1mm) x 3, 4; 8 x 4, 5-1/2OD(139.7mm), 6- 1/2OD(165.1mm),	300
XGQT03	EQUAL TEE	1, 1-1/4, 1-1/2, 2, 2-1/2, 3OD(76.1mm), 3, 4-1/4OD(108.1mm), 4, 5- 1/4OD(133 mm), 5-1/2OD(139.7mm), 6-1/4OD(159 mm), 6-1/2OD(165.1mm), 6, 8, 10, 12	300
XGQT04	GROOVED INC REASING BRA NCH	2 x 1, 1-1/4, 1-1/2; 2-1/2 x 1-1/4, 1-1/2, 2; 3OD(76.1mm) x 1-1/2, 2; 3 x 1-1/2, 2, 2-1/2, 3OD(76.1mm); 4-1/4OD(108mm) x 3OD(76.1mm), 3; 4 x 2, 3OD(76.1mm), 2-1/2, 3; 5-1/2OD(139.7mm) x 2, 3OD(76.1mm), 3, 4; 6-1/4 OD(159.1mm) x 3OD(76.1mm), 3, 4-1/4OD(108mm), 4; 6-1/2OD(165.1mm) x 2, 3OD(76.1mm), 3, 4, 5- 1/2OD(139.7mm); 6 x 2, 2-1/2, 3OD(76.1mm), 3, 4; 8 x 4, 5-1/2OD(139.7mm), 6-1/4 OD(159.1mm), 6- 1/2OD(165.1mm), 6;	300
XGQT04S	THREADED IN	2 x 1, 1-1/4, 1-1/2;	300

Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

Page 4 of 5



원본대조필



CERTIFICATE OF COMPLIANCE(UL)

CERTIFICATE OF COMPLIANCE

Certificate Number 20160914-EX26750
Report Reference EX26750-20150831
Issue Date 2016-SEPTEMBER-14

CREASING BR ANCH	2-1/2 x 1-1/4, 1-1/2, 2; 3OD(76.1mm) x 1, 1-1/4, 1-1/2, 2; 3 x 1, 1-1/4, 1-1/2, 2, 3OD(76.1mm); 4-1/4OD(108mm) x 3OD(76.1mm), 3; 4 x 1, 1-1/4, 1-1/2, 2, 2-1/2, 3OD(76.1mm), 3; 5-1/2OD(139.7mm) x 1, 1-1/4, 1- 1/2, 2, 3OD(76.1mm), 3; 6-1/4OD(159.1mm) x 3OD(76.1mm), 3; 6-1/2OD(165.1mm) x 1, 1-1/4, 1- 1/2, 2, 3OD(76.1mm), 3; 6 x 1, 1-1/4, 1-1/2, 2, 2-1/2, 3; 8 x 3OD(76.1mm), 3;		
XGQT8	FLANGE ADAPTER	2, 2-1/2, 3OD(76.1mm), 3, 4-1/4OD(108.1mm), 4, 5- 1/4OD(133mm), 5-1/2OD(139.7mm), 6- 1/4OD(159mm), 6-1/2OD(165.1mm), 6, 8;	300



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

Page 5 of 5



원본대조필



CERTIFICATE OF COMPLIANCE(UL)

CERTIFICATE OF COMPLIANCE

Certificate Number EX28392
Report Reference EX28392-2021-05-13
Date 2021-May-25

Issued to: CYKB CO., LTD
East of Hope Avenue, North of Weisan Road, Hope New
District, Mengcun County,
CangzhouHebei 041400 CN

This is to certify that
representative samples of
FITTINGS, GROOVED AND PLAIN END

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: Subject 213C - Outline of Investigation for Grooved and
Plain End Fittings

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up
Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's
Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

Page 1 of 3



원본대조필



CERTIFICATE OF COMPLIANCE(UL)

CERTIFICATE OF COMPLIANCE

Certificate Number EX28392
Report Reference EX28392-2021-05-13
Date 2021-May-25

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

USL - Grooved end ductile iron fittings for use with Listed Rubber Gasketed Fittings for sizes and working pressures as shown below:

The following fittings are intended for use with SHANDONG ZHIHUA PIPE INDUSTRY CO LTD (EX26867) Listed rubber gasketed fittings.

Model	Fitting Type	Size, in(mm).	Rated Pressure, psi
YK1	90° elbow	60.5mm, 76.3mm, 89.1mm, 114.3mm, 139.8mm, 165.2mm	300
YK2	45° elbow	60.5mm, 76.3mm, 89.1mm, 114.3mm, 139.8mm, 165.2mm	300
YK3	Reducing Tee, Grooved	76.3mm x 60.5mm; 89mm x 60.5mm, 76.3mm; 114.3mm x 60.5mm, 76.3mm, 89.1mm; 139.8mm x 60.5mm, 76.3mm, 89.1mm, 114.3mm; 165.2mm x 60.5mm, 76.3mm, 89.1mm, 114.3mm, 139.8mm	300
YK4	Tee, Grooved	60.5mm, 76.3mm, 89.1mm, 114.3mm, 139.8mm, 165.2mm	300

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

Page 2 of 3



원본대조필



CERTIFICATE OF COMPLIANCE(UL)

CERTIFICATE OF COMPLIANCE

Certificate Number EX28392
Report Reference EX28392-2021-05-13
Date 2021-May-25

YK5	Reducing Tee, Grooved x Threaded	76.3mm x 42.7mm, 48.6mm, 60.5mm; 89.1mm x 42.7mm, 48.6mm, 60.5mm; 114.3mm x 42.7mm, 48.6mm, 60.5mm; 139.8mm x 42.7mm, 48.6mm, 60.5mm; 165.2mm x 42.7mm, 48.6mm, 60.5mm	300
YK6	Concentric Reducer, Grooved	76.3mm x 60.5mm; 89.1mm x 60.5mm, 76.3mm; 114.3mm x 60.5mm, 76.3mm, 89.1mm; 139.8mm x 60.5mm, 76.3mm, 89.1mm, 114.3mm; 165.2mm x 60.5mm, 76.3mm, 89.1mm 114.3mm, 139.8mm	300
YK7	Concentric Reducer, Grooved x Threaded	76.3mm x 42.7mm, 48.6mm, 60.5mm; 89.1mm x 42.7mm, 48.6mm, 60.5mm; 114.3mm x 42.7mm, 48.6mm, 60.5mm; 139.8mm x 42.7mm, 48.6mm, 60.5mm; 165.2mm x 42.7mm, 48.6mm, 60.5mm	300
YK8	Flange Adapter	60.5mm, 76.3mm, 89.1mm, 114.3mm, 139.8mm, 165.2mm	300
YK9	Cap	60.5mm, 76.3mm, 89.1mm, 114.3mm, 139.8mm, 165.2mm	300



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

Page 3 of 3



원본대조필

